
# 8LB6EL5


MODUŁ ŚWIATŁA CIĄGŁEGO, Ø62, ŻÓŁTY, BEZ ŻARÓWKI



| | | | | |
|---|---|---|---|---|
| **Charakterystyka ogólna** | | | | |
| Średnica | | | mm - inch | 62 / 2.44 |
| Kolor | | | | Żółty |
| Stopień ochrony według IEC | | | | IP54 |
| **Właściwości mechaniczne** | | | | |
| Moment obrotowy dokręcania zacisków maks. | | | Nm | 0.5 |
| Zacisk śrubowy | | | | Zaciski śrubowe |
| Przekrój przewodu | | | | |
| | AWG/Kcmil | | | |
| | | maks. | | 16 |
| | IEC | | | |
| | | maks. | mm² | 1.5 |
| Masa | | | g | 60 |
| **Warunki otoczenia** | | | | |
| Temperatura | | | | |
| | Temperatura pracy | | | |
| | | min. | °C | -20 |
| | | maks. | °C | +50 |


## Wymiary




## Schemat połączeń elektrycznych


The characteristics described in this document are subject to updates or modifications at any time. The descriptions, technical and functional information, illustrations and instructions in this brochure are purely illustrative, and are consequently not contractually binding




## Certyfikaty i zgodność

| | |
|---|---|
| Zgodność | |
| | IEC/EN 60947-1 |
| | IEC/EN 60947-5-1 |
| Certyfikaty | |
| | EAC |

## Klasyfikacja ETIM

| | |
|---|---|
| ETIM 8,0 | EC000232 - Moduł świetlny dla kolumny sygnalizacyjnej |


The characteristics described in this document are subject to updates or modifications at any time. The descriptions, technical and functional information, illustrations and instructions in this brochure are purely illustrative, and are consequently not contractually binding